

# Certificate of Constancy of Performance

This is to certify that:

Pegler Limited  
Belmont Works  
St Catherines Avenue  
Doncaster  
DN4 8DF  
United Kingdom

Holds Certificate Number:

0086-CPR-603441

In respect of:

**BS EN 331:1998+A1:2010 Manually operated ball valves and closed bottom taper plug valves for gas installations for buildings**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the above construction product. This certificate attests that all the provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above standard(s) under system 1 are applied and that the product fulfils (products fulfil) all the prescribed requirements set out above. This certificate remains valid as long as the test methods and/or factory production control requirements included in the harmonised standard(s), used to assess the performance of the declared essential characteristics, do not change and the products(s), and the manufacturing conditions in the plants(s) are not modified significantly.

For and on behalf of BSI, a Notified  
Body for the above Regulation  
(Notified Body Number 0086):

  
Chris Lewis - Certification Director, Product Certification

First Issued: 2014-03-17

Latest Issue: 2017-10-05

Page: 1 of 2

...making excellence a habit.™

# Certificate of Constancy of Performance

No. 0086-CPR-603441

**Manufacturing Plant (s):** Zhejiang New Dongsheng Industrial Co.,Ltd  
No.117 Dayuanxi Road  
Economic Development Zone  
Tonglu, Zhejiang, 311508  
China

Pegler (Yorkshire) Jiangmen Plumbing & Heating Ltd  
No. 98 Longxi Road  
Jiangmen, Guangdong, 529000  
China

## Product Information

Model No.	Model Sizes	Connection
PB300	15mm, 22mm, 28mm, 35mm, 42mm, 54mm	Compression
PB500	1/4", 3/8", 1/2", 3/4", 1", 1 1/4", 1 1/2", 2"	F x F (ISO 7)
PB700	1/4", 3/8", 1/2", 3/4", 1", 1 1/4", 1 1/2", 2"	F x F (ISO 7)

## Supplementary Information

<b>Gas family</b>	1st, 2nd & 3rd Families		
<b>Pressure Class</b>	MOP 5 (external to buildings)	<b>Release of dangerous substances</b>	N/A
<b>High Temperature Pressure Class:</b>	MOP 1 (internal to buildings)	<b>Resistance to high temperature</b>	≤ 150 dm <sup>3</sup> /h at 650°C for 30 min
<b>Nominal size</b>	15mm to 54mm (PB300) 1/4" – 2" (PB500 & PB700)		
<b>Temperature Class</b>	-20°C to +60°C	<b>Mechanical strength</b>	
<b>Rated Flowrate</b>	Pass	- Torque and Bending	Pass
		- Operating Torque	Pass
<b>Dimensional tolerances:</b>	±0.1 mm	- Stop resistance	Pass
<b>Internal pressure:</b>		<b>Durability</b>	
- pressure class:	5 bar (0.5 MPa)	- Endurance	Pass
- leak- tightness	≤20 cm <sup>3</sup> /h	- Resistance to low temperature	Pass
<b>Tightness (gas):</b>		- Salt spray resistance	N/A
- leak-tightness:	≤20 cm <sup>3</sup> /h	- Resistance to humidity	Pass

First Issued: 2014-03-17

Latest Issue: 2017-10-05

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).