

Keymark Certificate

This is to certify that:

Pegler Yorkshire Group Limited
Belmont Works
St Catherine's Avenue
Doncaster
South Yorkshire
DN4 8DF
United Kingdom

Holds Certificate Number:

003-CCC3-E00002

In respect of:

BS EN 215
Thermostatic Radiator Valves

The right and certificate to use the CEN/CENELEC Internal Regulations.

The CEN/CENELEC European Mark System, governing the use of the Keymark, which may be periodically updated by CEN/CENELEC and the Specific CEN Keymark Scheme Rules for Thermostatic Radiator Valves. The Keymark is authorized to be affixed to products manufactured at the above address and in conformity with the stated European Standards detailed in the following pages(s).

For and on behalf of BSI:

Gary Fenton, Global Product Certification Director

First Issued: 28/04/1995

Latest Issue: 20/04/2017



Keymark Certificate

No. 003-CCC3-E00002

EN 215 Thermostatic Radiator Valves

Terrier II Two Way

Thermostatic radiator valve / sensor head integral

Terrier II Two Way Chrome

Thermostatic radiator valve / sensor head integral

Terrier III

Thermostatic radiator valve / sensor head integral

Belmont

B1301-0/4 Thermostatic radiator valve / sensor head integral

B1401-0/4 Thermostatic radiator valve / sensor head remote

B1701-0/4 Thermostatic radiator valve / sensor head remote

Mistral II

Thermostatic radiator valve / sensor head integral

Mistral II Chrome

Thermostatic radiator valve / sensor head integral

Bulldog

Thermostatic radiator valve / sensor head integral

PTS Boss TRV

Thermostatic valve / sensor head integral



First Issued: 28/04/1995

Latest Issue: 20/04/2017

Page: 2 of 7

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Keymark Certificate

No. 003-CCC3-E00002

EN 215 Thermostatic Radiator Valves

PTS Boss TRV Chrome

Thermostatic radiator valve / sensor head integral

Regis

Thermostatic radiator valve / sensor head integral

Regis Chrome

Thermostatic radiator valve / sensor head integral

Regis II Chrome

Thermostatic radiator valve / sensor head integral



First Issued: 28/04/1995

Latest Issue: 20/04/2017

Page: 3 of 7

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Keymark Certificate

No. 003-CCC3-E00002

EN 215 Thermostatic Radiator Valves

Plumbase Contract

Thermostatic radiator valve / sensor head integral



First Issued: 28/04/1995

Latest Issue: 20/04/2017

Page: 4 of 7

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Keymark Certificate

No. 003-CCC3-E00002

EN 215 Thermostatic Radiator Valves

CEN Information declared by manufacturer

Terrier TRV Range

1/2" x 15mm Angle TRV Valve
1/2" x 15mm Straight TRV Valve
1/2" x 15mm Mistral II Angle TRV Valve
1/2" x 15mm Mistral II Straight TRV Valve
Terrier Thermal Head
Terrier Thermal Head Chrome Plated
Terrier III
Mistral II Thermal Head
Mistral II Thermal Head Chrome
PTS Boss TRV
PTS Boss TRV Chrome
Bulldog
Regis
Regis Chrome Plated Thermal Head
Iflo contract
Regis II
Regis II Chrome Plated
Bulldog Gen 2 Thermal Head

Nominated Flow Rates

| | |
|--|----------|
| 1/2" x 15mm Angle TRV Valve Forward and Reverse Flow | 190 kg/h |
| 1/2" x 15mm Straight TRV Valve Forward and Reverse Flow | 190 kg/h |
| 1/2" x 15mm Mistral II Angle TRV Valve Forward and Reverse Flow | 190 kg/h |
| 1/2" x 15mm Mistral II Straight TRV Valve Forward and Reverse Flow | 190 kg/h |
| Terrier III | 190 kg/h |

Hysteresis

| | |
|-------------------|--------|
| All Thermal Heads | 0.75 K |
| Terrier III | 0.6 K |

Differential Pressure Influence

| | |
|-------------------|--------|
| All Thermal Heads | 0.15 K |
| Terrier III | 0.1 K |

Water Temperature Influence

| | |
|---------------------------------------|-------|
| Thermal Heads with plain base | 0.9 K |
| Thermal Heads with Chrome plated base | 1.2 K |
| Terrier III | 1.1 K |

Response Time

| | |
|-------------------|--------|
| All Thermal Heads | 20 min |
| Terrier III | 20 min |

First Issued: 28/04/1995

Latest Issue: 20/04/2017

Page: 5 of 7

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Keymark Certificate

No. 003-CCC3-E00002

EN 215 Thermostatic Radiator Valves

CEN Information declared by manufacturer

Terrier Décor TRV Range

1/2" x 15mm Angle TRV Valve

1/2" x 15mm Straight TRV Valve

Terrier Decor White Thermal Head

Terrier Decor Anthracite Thermal Head

Terrier Decor Chrome Thermal Head

Nominated Flow Rates

1/2" x 15mm Angle TRV Valve Forward and Reverse Flow

190 kg/h

1/2" x 15mm Straight TRV Valve Forward and Reverse Flow

190 kg/h

Hysteresis

All Thermal Heads

0.62 K

Differential Pressure Influence

All Thermal Heads

0.08 K

Water Temperature Influence

Chrome Thermal Heads


0.9 K

White and Anthracite Thermal Heads

1.2 K

Response Time

All Thermal Heads 20 mins



First Issued: 28/04/1995

Latest Issue: 20/04/2017

Page: 6 of 7

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Keymark Certificate

No. 003-CCC3-E00002

EN 215 Thermostatic Radiator Valves

CEN Information declared by manufacturer

Belmont and Boss Range

1/2" Vertical TRV valve
1/2" Vertical TRV valve pre-setting
1/2" Horizontal TRV valve
1/2" Horizontal TRV valve pre-setting
1/2" Straight TRV valve
1/2" Straight TRV valve pre-setting
3/4" Vertical TRV valve
3/4" Vertical TRV valve pre-setting
3/4" Horizontal TRV valve
3/4" Horizontal TRV valve pre-setting
3/4" Straight TRV valve
3/4" Straight TRV valve pre-setting
Standard Thermal Head
Remote Sensing Thermal Head
Remote Adjusting Thermal Head

Nominated Flow rates

1/2" Angle and reverse angle forward flow
1/2" Angle and reverse angle reverse flow
1/2" Straight pattern forward and reverse flow
3/4" patterns 265 kg/h

206 kg/h
220 kg/h
195 kg/h

Hysteresis

0.5 K

Differential Pressure influence

All variants forwards
All variants reverse -

0.15 K
0.25 K

Water Temperature Influence

Fixed thermal head
Remote sensing and remote adjusting heads

0.9 K
0.5 K

Response time

All TRV head variants - vertical
All TRV head variants - horizontal

24 minutes
20 minutes

First Issued: 28/04/1995

Latest Issue: 20/04/2017

Page: 7 of 7

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.